Type of Business or Facility	Design Flow (gallons per day)
Assisted Living/Residential Care Home	
 Per resident bed space, ambulatory residents 	100
 Per resident bed space, non-ambulatory residents 	125
- Live-in caregiver	75
- Per employee (day use)	15
Camps (per person)	
- Day use	10
 Overnight use, with flush toilets, no showers 	25
 Overnight use, with flush toilets and showers 	35
Churches and assembly halls (per seat)	
- Without kitchen	5
- With kitchen	15
Country clubs	
 Per resident member or caretaker 	75
- Per guest	25
- Per employee	15
Day care (per patron, employee)	15
Detention center	
 Per resident bed space 	100
- Per employee	15
Factories and industrial buildings (toilet waste only)	
 Without showers (per employee) 	15
- With showers (per employee)	35
Hotels or motels	
- Per guest	50
- Per employee	15
 Additional for restaurant, spa or other facilities 	Case-by-case
Laundromat, with self-service washing machines	4
- Per machine	500
or	
- Per customer	50
Mobile home parks (per space)	250
Multiunit residential housing	
- Apartments, per bedroom	150
 Boarding house and farm labor housing, per bed 	50
Office and stores (per employee)	15

	(gallons per day)
Parks with picnic areas (per person)	
- With flush toilets	5
- With flush toilets and showers	10
Recreational vehicle parks	
 Without individual sewer hook-ups (per space) 	50
 With individual sewer hook ups (per space 	100
Restaurants and Food Service	
 Toilet and kitchen wastes (per patron) 	10
- Kitchen wastes only (per meal served)	5
- Addition for bars (per patron)	2
- Per employee	15
Service Station	
- per vehicle served	10
- per employee	15
Schools, boarding	
- student and live-in staff (per person)	75
- daily staff (per person)	15
Schools, day	
- without cafeteria or showers (per student)	15
- with cafeteria (per student)	20
- with cafeteria and showers (per student)	25
- staff (per person)	15
Swimming pools	10
per patronper employee	10
Theaters	15
- per seat	E
per seat per employee	5 15
Wineries (sanitary waste only)	10
- tasting room, per visitor	2.5
- per employee	15
- special events	Case-by-case

<u>Source</u>: U.S. Environmental Protection Agency. *Onsite Wastewater Treatment Systems Manual Revised 2002, Chapter 3: Establishing Treatment System Performance Requirements.*